



No.C-592/2019

*Office of the Station Officer
Fire & Rescue Station,
Thiruvalla.
Date: 13-12-2019*

CERTIFICATE OF EXEMPTION FROM NOC

The application for obtaining NOC submitted to this office by The Manager, Gurukul Mount Public School Mundukuzhy, Kunnamthanam has been verified by me on 13.12.2019 regarding the existing building in Survey No.3/1-1 of Kunnamthanam village ,Mallappally Thaluk in Pathanamthitta District under Kunnamthanam Gramapanchayath

On inspection, it is found that all fire fighting systems were correct and in good working condition

The height and plinth area of the educational building are less than 15 mtr and 1000 m² respectively and found to be exempted from Fire NOC KMBR / KPBR vide Govt orders F2-103/19 Home dtd 02-04-2019 , GO(P)No.81/2017/LSGD dtd 31-10-2017 and GO (P) No.82/2017/LSGD , 31-10-2017 under the “**Ease of Doing Business**” policy

Hence it is certified that the aforesaid building is exempted from acquiring NOC from Fire and Rescue Services Department as per the conditions prescribed in the order cited above

This certificate is issued to CBSE, New Delhi in connection with extension of affiliation



[Signature]
**STATION OFFICER
FIRE AND RESCUE STATION
THIRUVALLA**

To,
The Applicant.