



No. frstvl/516/2025-C

*Office of the Station Officer
Fire & Rescue Station,
Thiruvalla.
Date: 18/06/2025*

CERTIFICATE OF EXEMPTION FROM NOC

The applicaiton for obtaining NOC submitted to this office by The Manager, Gurukul Mount Public School, Mundukuzhy, Kunnamthanam has been verified by me on 18/06/2025 regarding the existing building in Survey No. 3/1-1 of Mallappally Thaluk, Kunnamthanam Village, in Pathanamthitta district under Kunnamthanam Grammapanchayath.

On inspection it is found that all firefighting systems were correct and in good working condition.

The height and plinth area of the Mercantile Building are less than 15 mtr. and 1000 m2 respectively and found to be exempted from Fire NOC KMBR / KPBR vide Govt Orders F2-103/19 Home dtd. 02/04/2019, GO(P) No. 81/2017/LSGD dtd. 31/10/2017 and GO(P) NO. 82/2017/LSGD, 31/10/2017 under the "Ease of Doing Business" policy.

Hence it is certified that the aforesaid Buildings is Exempted from acquiring NOC from Fire and Services Department as per the conditions prescribed in the order cited above.

This certificate is issued to CBSE, New Delhi in connection with with extension of affiliation.

However, you must have obtained a Fire Safety Certificate as per Standing Order No. 10/2019 dated 23/07/2019 Of Director General, Fire and Rescue Services, Thiruvananthapuram.



Signed by

Sambhu Nampoothiry M K

Date: 18-06-2025 13:23:03

STATION OFFICER
FIRE AND RESCUE STATION
THIRUVALLA

To,

1. The Secretary, Kunnamthanam Grammapanchayath.
2. The Applicant.