



KERALA WATER AUTHORITY
QUALITY CONTROL SUB DISTRICT LABORATORY
PULIKKEEZHU, THIRUVALLA

Telephone No. 0469 2999833, Email :kwaqcsdlplkz@gmail.com

TEST REPORT

Report No:1261 /PLKZ/03/2025(MB)		Date: 14 .03.2025
GURUKUL MOUNT PUBLIC SCHOOL MUNDUKUZH PALACKATHAKIDI P.O KUNNAMTHANAM	1.Date of Payment Received	13.03.2025
	2. Date of Sample Received	13.03.2025
	3. Time of Sampling	12.13 pm
	4. Sampling done by	CUSTOMER
	5. Sample Code	2025/QCSDL/PLKZ/P1265
	6. Source of Sample	Drinking Water
	7. Sampling Method	Not Applicable
	8. Sample Quantity	200 ml
	9.Test performing dates	From:13.03.2025 To:14.03.2025

BACTERIOLOGICAL ANALYSIS

Sl. No	Parameters	Acceptable limits as per IS 10500 - 2012	Test Method	Result
1	Total Coliforms	Shall not be detected/100 ml	IS 15185 : 2021	ABSENT
2	<i>E. coli</i>	Shall not be detected/100 ml	IS 15185 : 2021	ABSENT

Remarks: -

NB: -The results stated above related only to the sample(s)submitted for testing. This test Certificate shall not be reproduced except in full without the written approval of the Laboratory.

QUALITY CONTROL SUB DISTRICT LABORATORY
KERALA WATER AUTHORITY
PULIKKEEZHU, THIRUVALLA

Verified By

Name: Deepa Raj C.S.

Bacteriologist